

Orange County Fire Authority

Community Risk Reduction

1 Fire Authority Road, Building A, Irvine, CA. 92602 www.ocfa.org 714-573-6180

Plant Processing and Extraction Facilities



Guideline G-16

Serving the Cities of Aliso Viejo • Buena Park • Cypress • Dana Point • Irvine • Laguna Hills • Laguna Niguel • Laguna Woods • Lake Forest • La Palma • Los Alamitos • Mission Viejo • Placentia • Rancho Santa Margarita • San Clemente • San Juan Capistrano • Seal Beach • Santa Ana • Stanton • Tustin • Villa Park • Westminster • Yorba Linda • and Unincorporated Areas of Orange County

Plant Processing and Extraction Facilities

PURPOSE

Orange County Fire Authority (OCFA) has prepared this guideline to provide minimum requirements on local interpretations and practices that are considered to be in compliance with the 2016 California Fire Code (CFC). This guideline is intended to provide information on plant processing and extraction facilities. The requirements of this guideline shall not be construed as altering any existing code, law or regulation which may require fire protection features not covered or alluded to in these requirements, nor shall they waive any requirements of any code, law or regulation. The reader is cautioned that the guidance detailed in this policy may or may not apply to their specific situation, and that the Authority Having Jurisdiction (AHJ) retains final authority to determine compliance.

This guideline covers the installation, maintenance, operation and permitting requirements as they pertain to Plant Processing and Extraction Facilities in new and existing facilities under the jurisdiction of the OCFA in accordance with CFC Sections 1.11.2.4, 102.9, 104.1, and 104.9.

SCOPE

This guideline applies to the following:

- The extraction process, including but not limited to, the act of extraction of the oils and fats by use of a solvent, de-solventing of the raw material and production of the miscella, distillation of the solvent from the miscella and solvent recovery.
- The use, storage, handling, and transferring of hazardous materials (e.g. flammable/combustible solvents) in these facilities.

Existing buildings or facilities where the processing or extraction of plants is introduced, changed, or where the medium of extraction or solvent is changed shall comply with this guideline. This document does not apply to cultivation grow facilities or to cannabis dispensaries.

Design and installation shall comply with the applicable provisions of the California Mechanical and Electrical Codes, as amended, and this guideline. The most restrictive requirements shall govern.

Codes and Standards

This policy is based on the 2016 CFC, Chapter 1, Section 102.9. Matters not provided for; Chapter 9, Fire Protection Systems; and Part V (Chapters 50 through 67) Hazardous Materials.

Specifically, CFC Section 102.9 permits the fire code official to determine requirements that are essential for the public safety of an existing or proposed activity, building or structure, or for the safety of the occupants thereof, which are not specifically provided for by the CFC.

This Guide is based upon the recently incorporated provisions to the Fire Code including, but not limited to, a new Section 916 for Gas Detection Systems and a new Chapter 38 for Plant Processing and Extraction Facilities. The California State Fire Marshal is supplementing the 2016 CFC with these 2018 International Fire Code provisions which will be effective statewide in July 2018.

Definitions

MISCELLA: A mixture, in any proportion, of the extracted oil or fat and the extracting solvent.

GAS DETECTION SYSTEM: A system or portion of a combination system that utilizes one or more stationary sensors to detect the presence of a specified gas at a specified concentration and initiate one or more responses required by this guideline such as notifying a responsible person, activating an alarm system, or activating/deactivating equipment. A self-contained gas detection and alarm device is not classified as a gas detection system.

SUBMITTAL REQUIREMENTS

PERMITS:

- **Plant extraction systems.** A plan review and operational permit is required for installation of or modification to a plant extraction system. Maintenance performed in accordance with the CFC is not considered to be modification and does not require a permit.
- **Gas detection systems.** A plan review and operational permit is required for installation of or modification to gas detection systems. Maintenance performed in accordance with the CFC is not considered a modification and shall not require a permit.

REQUIREMENTS:

Plans shall be submitted to OCFA for all plant extraction systems. The plans may be separated into individual plans sets for:

- Process equipment, industrial ovens, tanks, etc.
- Gas detection
- H occupancy
- Fire master plan
- Architectural (only if H or L occupancy)
- Fire sprinklers
- Chem class

Additionally, comply with any additional permit applications and review requirements of the City Building and Safety Department. Applicable plan review and permit fees shall apply.

GENERAL REQUIREMENTS

Construction drawings and specifications shall bear the seal and signature of a licensed California professional engineer/architect who prepared the drawings/specifications and shall be complete and of sufficient clarity to indicate the entire work proposed and show in detail that

the plant extraction system conforms to the provisions of this guideline and relevant laws, codes, ordinances, rules and regulations. Each set of drawings and specifications shall, at a minimum, contain the following information:

- A. Exact address, legal description of the property and location of the work performed.
- B. Name and address of the business owner and property owner.
- C. Name and address of the person or firm responsible for the preparation of the drawings and specifications. The seal and signature of the California licensed architect and/or engineer responsible for the preparation of the drawings and specifications.
- D. Two complete sets of construction documents showing the construction of architectural, structural, mechanical, plumbing and electrical arrangements.
- E. One copy of specifications or notes that clearly describe the type, quality and finish of materials and the method of assembly, erection and installation of equipment to be installed with proper reference to accepted standards.
- F. Except for entirely interior installations, a plot plan showing the location of the proposed construction (i.e., tanks) and the location of every adjacent existing building on the property, roads, walks, utilities and other site improvements, all property lines, streets, alleys, easements and other public areas.
- G. Bulk tank installations may require an engineered structural foundation with a separate tank installation permit. Contact the City Building and Safety Department to determine requirements.
- H. Total aggregate quantity of hazardous materials (solvents, etc.) in storage and in use.
- I. Location of the room where the plant extraction operation will be conducted. Identify whether the room is above or below grade.
- J. Location of containers relative to equipment, building openings and means of egress.
- K. Manufacturer's specifications and pressure rating, including cut sheets, of all piping and tubing to be used.
- L. A piping and instrumentation diagram (P&ID) that shows piping support and remote fill connections.
- M. Details of container venting, including but not limited to vent line size, material and termination location.
- N. Alarm and detection system and equipment.
- O. Seismic support for containers.

SITE INSPECTION:

OCFA and the City Building and Safety Department shall inspect and witness acceptance testing of the installation. Contact OCFA and the City Building and Safety Department to confirm type and frequency of inspections required. Compliance with all CFC requirements shall be maintained at all times.

OPERATIONAL PERMITS:

Where required by the Fire Code Official, operational permits shall be issued upon final inspections and approvals of construction and equipment installation.

An annual operational permit will be required to use a plant extraction system in accordance with the CFC and this guideline. Operational permits shall be posted on site.

SPECIFIC SYSTEM REQUIREMENTS
PROCESSING AND EXTRACTION:

- A. Construction:** Processing shall be located in a building complying with the California Building Code.
- B. Prohibited occupancies:** Extraction processes utilizing flammable gases or flammable cryogenic fluids shall not be located in any building containing a Group A, E, I or R occupancy.
- C. Location:** The extraction equipment and extraction process utilizing hydrocarbon solvents shall be located in a room or area dedicated to extraction.
- D. Post-process purification and winterization:** Post-processing and winterization involving the heating or pressurizing of the miscella to other than normal pressure or temperature shall be approved and performed in an appliance listed for such use. Domestic or commercial cooking appliances shall not be used.
- E. Industrial ovens:** The use of industrial ovens shall comply with CFC Chapter 30.
- F. Use of flammable and combustible liquids:** The use of flammable and combustible liquids for liquid extraction processes where the liquid is boiled, distilled, or evaporated shall be located within a hazardous exhaust fume hood, rated for exhausting flammable vapors. Electrical equipment used within the hazardous exhaust fume hood shall be rated for use in flammable atmospheres. Heating of flammable or combustible liquids over an open flame is prohibited.
Exception: The use of a heating element not rated for flammable atmospheres may be approved where documentation from the manufacture or approved testing laboratory indicates it is rated for heating of flammable liquids.
- G. Liquefied Petroleum Gas:** Liquefied-petroleum gases shall not be released to the atmosphere.
Exception: LPG gas may be released to the atmosphere in accordance with the 2014 edition of NFPA 58 Section 7.3.

SYSTEMS AND EQUIPMENT:

- A. **Systems and equipment:** Systems or equipment used for the extraction of oils from plant material shall be listed or approved for the specific use. If the system used for extraction of oils and products from plant material is not listed, then the system shall be reviewed by a Licensed California Professional Engineer. The Engineer shall review and consider any information provided by the system's designer or manufacturer. For systems and equipment not listed for the specific use, a technical report in accordance with the below requirements shall be prepared and submitted to the fire code official for review and approval. The firm or individual preparing the technical report shall be approved by the fire code official prior to performing the analysis.
- B. **Technical report:** The technical report which has been reviewed and approved by the fire code official, as required by the section above is required prior to the equipment being located or installed at the facility. The report shall be prepared by an Engineer or other professional approved by the fire code official. The technical report shall contain all of the following:
- Manufacturer information (name, company, phone/email contacts).
 - Preparer of record on technical report.
 - Date of review and report revision history.
 - Signature page shall include all of the following, Author, Date, Seal and Signature of the Engineer
 - Model number of the item evaluated. If the equipment is provided with a serial number, the serial number shall be included for verification at time of site inspection.
 - Methodology of the design or peer review process used to determine minimum safety requirements. Methodology shall consider the basis of design, and shall include a code analysis and code path to demonstrate the reason as to why specific code or standards are applicable or not.
 - Equipment description. A list of every component and sub-assembly (fittings, hose, quick disconnects, gauges, site glass, gaskets, valves, pumps, vessels, containers, switches, etc.) of the system or equipment, indicating the manufacturer, model number, material, and solvent compatibility. Include manufacturers' data sheets.
 - A general flow schematic or general process flow diagram of the process. Post-processing or winterization shall be included in this diagram. All primary components of the process equipment shall be identified and match the equipment list above. Operating temperatures, pressures, and solvent state of matter shall be identified in each primary step or component. A piping and instrumentation diagram (P&ID).

- Record of any pressure vessels, and spec sheets. Indicate if pipe is used for fabricated components.
- Structural analysis for the frame system supporting the equipment.
- Process safety analysis of the extraction system, from the introduction of raw product to the end of the extraction process.
- Comprehensive process hazard analysis (PHA) considering failure modes and points of failure throughout the process. The process hazard analysis shall include a review of emergency procedure information provided by the manufacturer of the equipment or process, assembly instructions, operation and maintenance manuals provided by the manufacturer.
- List of references used in the analysis.

C. **Site inspection:** Prior to operation of the extraction equipment, where required by the fire code official, the Engineer shall inspect the site of the extraction process once equipment has been installed for compliance with the technical report and the building analysis. The Engineer shall provide a report of findings and observations of the site inspection to the fire code official prior to the approval of the extraction process. The field inspection report authored by the Engineer include the serial number of the equipment used in the process and shall confirm the equipment installed is the same model and type of equipment identified in the technical report.

SAFETY SYSTEMS:

- A. **Gas detection system:** Rooms in which extraction processes utilizing flammable gases or liquids as solvents, are conducted shall be provided with a gas detection system that complies with this guideline.
- **System design:** The flammable gas detection system shall be listed or approved and shall be calibrated to the types of fuels or gases used for the extraction process. The gas detection system shall be designed to activate when the level of flammable gas exceeds 25 percent of the lower flammable limit (LFL). For nonflammable gases, a gas concentration exceeding one half of the IDLH, unless a different threshold is specified by this guideline or CFC requiring a gas detection system.
 - **Gas detection system components:** Gas detection system control units shall be listed and labeled in accordance with UL 864 or UL 2017. Gas detectors shall be listed and labeled in accordance with UL 2075 for use with the gases and vapors being detected.

Exception: Where there are no listed products available to comply with the provision in this section due to new and emerging technologies OCFA may grant a modification in accordance with CFC Section 104.8. In addition, the provisions of CFC Section 104.7.2 may be required to

demonstrate compliance with the intent and purpose of this guideline and the CFC.

- **Operation:** Activation of the gas detection system shall result in all of the following:
 - 1 Initiation of distinct audible and blue visual alarm signals in and out of the extraction room.
 - 2 Deactivation of all heating systems located in the extraction room.
 - 3 Activation of the mechanical ventilation system, where the system is interlocked with gas detection.

 - **Failure of the gas detection system:** Failure of the gas detection system shall result in the deactivation of the heating system, activation of the mechanical ventilation system where the system is interlocked with the gas detection system and cause a trouble signal to sound in an approved location.

 - **Interlocks:** All electrical components within the extraction room shall be interlocked with the gas detection system. Activation of the gas detection system shall disable all light switches and electrical outlets.
- B. **Emergency shutoff:** Extraction processes utilizing gaseous hydrocarbon based solvents shall be provided with emergency shutoff systems in accordance with CFC Section 5803.1.3
- **Power connections:** Gas detection systems shall be permanently connected to the building electrical power supply or shall be permitted to be cord connected to an unswitched receptacle using an approved restraining means that secures the plug to the receptacle.

 - **Emergency and standby power:** Standby or emergency power shall be provided or the gas detection system shall initiate a trouble signal at an approved location if the power supply is interrupted.
- C. **Signage:** Signs shall be provided adjacent to gas detection system alarm signaling devices that advise occupants of the nature of the signals and actions to take in response to the signal.
- D. **Fire alarm system connections:** Gas sensors and gas detection systems shall not be connected to fire alarm systems unless approved and connected in accordance with the fire alarm equipment manufacturer's instructions.
- E. **Inspection, testing and sensor calibration:** Inspection and testing of gas detection systems shall be conducted not less than annually. Sensor calibration shall be confirmed at the time of sensor installation and calibration shall be performed at the frequency specified by the sensor manufacturer.

